

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 404/D/SWA/NSA

Dated: 17/6/2025

It is certified that an inspection team headed by ALKA SINGH - CHEMIST

(Name of Officers with designation) from KANPUR NAGAR NIGAM PHED

inspected the VIDYA NIKETAN EDUCATION CENTRE, Anazi - 177, 178,

(Name & Address of the school) on 12/06/2025 (date of inspection) and on the basis of Sajasi, KANPUR

Water Test Report (Attached) bearing no. 303/SWA/CHEM dated 17/06/2025

of Public Health Laboratory K.N.N. (PHED Lab) certified that the

VIDYA NIKETAN EDUCATION CENTRE (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till

Signature with Seal: [Signature]
Name: [Signature]
Designation: नगर स्वास्थ्य अधिकारी
Name & Address of the [Signature] Department: नगर निगम कानपुर

To Vidya Niketan Education Centre
Anazi, 177, 178, Sajasi, Kanpur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the	M/S VIDYA NIKETAN EDUCATION CENTRE,
Sample taken from	'SUBMERCIBLE' ASAZI - 177, 179, Sajari, Kanpur
Date of sample Drawn	12/06/2025
Date of analysis	12/06/2025
Physical Character	TRANSPARENT / ODORLESS
P. H. Value	8.42
Free Ammonia Parts per 1000000	NIL
Albuminoid Ammonia Part per 1000000	NIL
Oxygen absorbed from pot. Permagnate in three hours at 37° C	0.6
Chloride Part per 1000000	28.00
Nitrates Parts per 1000000	TRACES
Nitrates Parts per 1000000	TRACES
Total solid part per 100000	540.00
Fixed solid Parts per 1000000	460.00
Volatils solid Parts per 100000	80.00
Appearance on ignition	NO CHARRING
Total hardness Parts per 1000000	196.00
Permanent hardness Parts per 1000000	170.00
Temporary hardness Parts per 1000000	26.00

K.N.N. PRESS

Remarks :

POTABLE

No. 303/SAN/2025 dated 17/06/2025


Copy forwarded for favour or information to

1) M/S Vidya Niketan Education Centre
Asazi - 177, 179, Sajari, Kanpur

Nagar Swasthya Adhikari
नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर

ATKA SINGH
(Chemist)

2) N.S.A. Kanpur Nagar Nigam Kanpur



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from

Name & designation of the person collecting samples..... ALKA SINGH - CHEMIST

WATER DIVISION
SAHAR, KANPUR NIGAM

D.No - 308/S&M/Chem. 17/06/2025

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count	Probable on of coliform organisms in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS		
		at 37.c in 48 hours	at room temp- pattern in 72 hours						
12/6/2025	BUSMAREBLE	141	561	—	NIL	20	20	NIL	SATISFACTORY

Remarks - Chlorination is Necessary / P.H.C. would be 0.2 PPM.

Copy for information forwarded to (1) Udyog Niketan, Lucknow Centre.

(2) M.S.A. Kanpur Nagar Nigam.

ALKA SINGH
(Chemist)
Nagar Sanjivani & Sahakar
एन सी एन एन
Nagar Nigam Kanpur